

TORK®

WFTU40

7-DAY TIME SWITCH

MULTI-VOLTAGE WI-FI TIMER

120/208 – 240/277VAC

| DESCRIPTION | FEATURES |
|---|--|
| <ul style="list-style-type: none"> Commercial grade Indoor/outdoor plastic case UL tested per UL/CSA  | <ul style="list-style-type: none"> Dual voltage ready DPST Contacts ON/OFF controls ON/OFF override Wi-Fi app ready Surge protected Two year warranty      |



| TYPE | VOLTAGE | NO | NC |
|------------|------------|-----------------|-------------------|
| | 60Hz | | |
| Resistive | 120-277VAC | 40A | 30A |
| | 28VDC | 20A | - |
| Inductive | 120-277VAC | 30A | 15A |
| Ballast | 120VAC | 30A | 10A |
| | 277VAC | 20A | 10A |
| Tungsten | 120VAC | 15A | - |
| Pilot Duty | 120VAC | 720 VA | - |
| | 125VAC | - | 290 VA |
| | 240VAC | 720 VA | 360 VA |
| Motor | 120VAC | 1HP 30FLA 90LRA | 1/4HP 12FLA 30LRA |
| | 240VAC | 2HP 20FLA 60LRA | - |
| | 250VAC | - | 1/2HP 12FLA 33LRA |




WARNING: Cancer and reproductive harm.
www.P65Warnings.ca.gov.




WIRING INSTRUCTIONS & DIAGRAM

Use copper wire AWG 8-18 suitable for 90°C. WIRING TO COMPLY WITH ALL LOCAL AND NATIONAL ELECTRICAL CODES. Bonding between conduit connection is not automatic and must be provided as part of the installation. THE ENCLOSURE MUST BE PROPERLY GROUNDED. Minimum 10.6 lb. in. torque required at the terminals to ensure proper connections. Strip the supply and load wires to 1/2".

Typical Wiring Diagram, 120/277VAC Application



Typical Wiring Diagram, 208-240 VAC Application



Scan with a mobile device for additional information.



FCC Statement: This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation of the device. FCC Caution: Any changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate this equipment.