

INSTALLATION INSTRUCTIONS

SNAT3165 – BLACK NEOPRENE TUBING

Used for HVACR Pressure Switches

Temperature rating is

0°F to 160°F (-17°C to 71°C)

Length: 5 ft.

Inside Diameter: 3/16"

1. Always disconnect power before working on the equipment.
2. Remove the old tubing and measure the length.
3. Clean the barbs to ensure there is no old hose or debris.
4. Cut new hose to proper length. Measure length from old hose if it is still intact.
5. Attach hose to barbs.
6. Reconnect power and test.



Disconnect power before
servicing equipment.

800.333.9125 - techsupport@supco.com - www.supco.com