INSTALLATION INSTRUCTIONS T45 TRANSFORMER

The T45 transformer can be used in any application where the transformer rating of 48 vol-amp (VA) is not exceeded.

Maximum continuous current is 2 amps in any secondary winding.



Disconnect power before servicing equipment.

- 1. Disconnect power before installing transformer.
- 2. Used enclosed wire nuts to make desired

connections to desired color-coded wires. NOTE: Leads not used must be insulated and taped to avoid shock hazard or short circuit.

Wiring Information For Primary (Input) V

120V - White + Black 208V - White + Red

240V = White + Yellow

For Secondary (output) V


2.5V - White + Yellow 8V - Yellow + Green


12V - Yellow + Red

24V - Green + Red

All Necessary hardware is included in the box.

T45 is designed for plate, foot, or knockout mounting.





800.333.9125 - techsupport@supco.com - www.supco.com